WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70475
Permit No.
Basin 212

NOTICE OF INTENT NO. 16559

1. OWNER Darby Nagle Enter
MAILING ADDRESS LV NV
ADDRESS AT WELL LOCATION On Tropicana E of Hollywood Cir

2. LOCATION S ¼ SE ¼ Sec 33 T. 21 N/S R. 62 E Clark County
PERMIT NO. DW-1882 (Issued by Water Resources) 161-22-881-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other BK

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 3 | 3 |
| Sand | | 3 | 6 | 3 |
| Sandy Silts w/ Clay lens | | 6 | 26 | 20 |
| Clay w/ Sand lense | | 26 | 36 | 10 |
| Sand & gravel | | 36 | 44 | 8 |
| Refusal | | | 44 | |

Date started 2-13 1998
Date completed 2-13 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 44 Feet Depth Cased 44 Feet

HOLE DIAMETER (BIT SIZE)
24 Inches From 0 Feet To 44 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | PVC | Sch 40 | 0 | 44 |

Perforations:
Type perforation Slot
Size perforation .005
From 14 feet to 44 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 44 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GDC (Contractor)
Address 536 E Maitland (Contractor)
Ontario CA
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1968
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-19-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627