

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 369912

1. OWNER A & N PIETERS ADDRESS AT WELL LOCATION 1754 BITTERBRUSH COURT  
 MAILING ADDRESS 1232 JONES RANCH RD GARDNERVILLE, NV 89410  
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T 13 S R 20 E Douglas County  
 PERMIT NO. 23 473 44 SUBDIVISION NAME WILDFLOWER CR

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SURFACE ALLUVIUM</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>SANDY LOAM TO ~</u>	<u>8 FT</u>			
<u>THEN MORE CLAY</u>				
<u>MORE CLAY IN VALLEY</u>		<u>20</u>	<u>80</u>	<u>60</u>
<u>FILL OR ALTERED VOL ALL</u>				
<u>MOSTLY CLAY WITH MINOR</u>		<u>80</u>	<u>180</u>	<u>100</u>
<u>SAND &amp; SMALL GRVL</u>				
<u>MOSTLY GRVL &amp; SAND</u>		<u>180</u>	<u>240</u>	<u>60</u>
<u>MINOR CLAYS</u>	<u>X</u>			
<u>MORE CLAY W MINOR</u>	<u>X</u>	<u>240</u>	<u>260</u>	<u>20</u>
<u>GRVL &amp; THIN BEDS OF</u>				
<u>SAND</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 260 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1 1/4 Inches 0 Feet 50 Feet  
1 3/8 Inches 50 Feet 260 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>260</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3 x 7/32  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 260 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 1/31 1998  
 Date completed 2/7 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60</u>	<u>—</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWIS CRK RD Contractor  
CARSON CITY, NV 89704  
 Nevada contractor's license number 13697A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1476  
 Division of Water Resources, the on-site driller  
 Signed Joe L. L...  
 by driller performing actual drilling on site or contractor  
 Date 2/10/98