


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

70746 OFFICE USE ONLY
 No. 70746
 Permit No. 162
 Basin


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17349

1. OWNER John & Elizabeth Eastin ADDRESS AT WELL LOCATION 1851. Keith
 MAILING ADDRESS 1851 E. Keith Pahrump, NV 89048

2. LOCATION SW 1/4 NE 1/4 Sec. 35 T 21S N/S R 53E E Nye County
 PERMIT NO. 41-333-08 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy clay		0	8	8
grey calache		8	12	4
white calache		12	16	4
See next line		16	22	6
grey clay & stringes of white calache				
grey calache		22	35	13
grey calache		35	47	12
grey calache		47	54	7
grey calache		54	65	11
grey clay & sand		65	68	3
brown clay & sand		68	75	7
greenish clay		75	80	5
brown clay		80	95	15
black gravel	x	95	105	10
brown clay & gravel	x	105	115	10
brown clay & gravel	x	115	130	15
brown clay & gravel	x	130	140	10
See next line	x	140	145	5
brown clay & sand rock & gravel				
brown clay & sand & gravel	x	145	160	15

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 160
 11 Inches Feet 160 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	160

Perforations:
 Type perforation saw cut
 Size perforation .188
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board. 40277
 Nevada driller's license number issued by the Division of Water Resources. The on-site driller. 2086
 Signed [Signature]
 By driller performing actual drilling on-site of contractor
 Date 3-17-98



Date started 3/14/98 19__
 Date completed 3/14/98 19__

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>na</u>	<u>.50</u>