

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 70748  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340.

NOTICE OF INTENT NO. 17343

1. OWNER John & Cynthia Gagnon ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1500 S. Meier  
Pahrump, NV 89048

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T 20S N/S R 52E E Nye County  
 PERMIT NO. 28-525-01 Rock-N-Horse Estates Subdivision Name  
 Issued by Water Resources Parcel No: \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition.  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material            | Water Strata | From | To  | Thickness |
|---------------------|--------------|------|-----|-----------|
| brown clay          |              | 0    | 2   | 2         |
| grey clay           |              | 2    | 8   | 6         |
| dark grey clay      |              | 8    | 12  | 4         |
| grey clay           |              | 12   | 20  | 8         |
| grey calache        |              | 20   | 25  | 5         |
| light brown clay    |              | 25   | 28  | 3         |
| grey clay           |              | 28   | 30  | 2         |
| brown clay          |              | 30   | 40  | 10        |
| grey clay           |              | 40   | 43  | 3         |
| brown clay          |              | 43   | 60  | 17        |
| brown clay          | x            | 60   | 70  | 10        |
| light brown calache | x            | 70   | 92  | 22        |
| brown clay          | x            | 92   | 120 | 28        |
| grey calache        | x            | 120  | 125 | 5         |
| grey clay           | x            | 125  | 140 | 15        |

8. WELL CONSTRUCTION  
 Depth Drilled: 140 Feet Depth Cased: 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet 140 Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 3.7                 | .280                    | 0           | 140       |

 Perforations:  
 Type perforation Saw Cut  
 Size perforation .188  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet  
 9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature: cold °F Quality good

Date started 3/9/98, 19\_\_\_\_  
 Date completed 3/9/98, 19\_\_\_\_

7. WELL TEST DATA

| TEST METHOD:   | TEST METHOD:                  |              |
|--|-------------------------------|--------------|
|  | G.P.M.                        | Time (Hours) |
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | Draw Down (Feet Below Static) |              |
| <u>.5</u>  | <u>na</u>                     | <u>.50</u>   |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 3-17-98