WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70751
Permit No.
Basin 162

NOTICE OF INTENT NO. 17345

1. OWNER Gail Murhoven
MAILING ADDRESS 2640 N. Blagg
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
2640 N. Blagg

2. LOCATION SE 1/4 NE 1/4 Sec. 33 T 19S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 29-841-18 (Parcel No.) Rancho Del Sol (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

6. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam		0	18	18
sand & brown clay		18	32	14
sand & brown clay		32	65	33
brown calache		65	68	2
brown calache	x	68	75	7
brown calache	x	75	93	18
brown calache	x	93	105	12
brown calache	x	105	113	8
brown calache & gravel	x	113	128	15
brwon calache & gravel	x	128	140	12
brown clay	x	140	155	15
brown clay	x	155	185	30

Date started 3/12/98, 19__
Date completed 3/12/98, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
11	0	185

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	185

Perforations:
Type perforation saw cut
Size perforation .188
From 145 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 185 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Larry Strickland
(By driller performing actual drilling on-site or contractor)

Date 3-17-98