

OFFICE USE ONLY
 Log No. 70825
 Permit No. 44
 Basin Elko

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35963

1. OWNER DEW INC ADDRESS AT WELL LOCATION Johnson & Kayenta Drive, Ryndon, Elko, NV
 MAILING ADDRESS P.O. Box 35
Elko NV 89803
 2. LOCATION SE 1/4 NE SE 1/4 Sec. 36 T. 36 N. S. R. 5 E. Elko County
 PERMIT NO. 006-334-030 Parcel No. Ryndon Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	2	2
CLAY		2	20	18
SAND & Gravel	X	20	24	4
CLAY		24	61	37
SANDSTONE		61	69	8
CLAY		69	100	31
SANDSTONE		100	103	3
CLAY		103	105	2
SOFT SANDSTONE	X	105	120	15

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.42</u>	<u>1.88</u>	<u>1</u>	<u>120</u>

Date started 12-24, 1997
 Date completed 1-2, 1997

Perforations:
 Type perforation Mill Slots
 Size perforation 3/16 x 2"
 From 10' feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 120 feet

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>6.5</u>	
<u>Open</u>			

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name FERTIG Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0031904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shoule Fertig
 By driller performing actual drilling on site or contractor
 Date 1-2-98