

OFFICE USE ONLY  
 Log No. 70861  
 Permit No. 23  
 Basin  
 NOTICE OF INTENT 10-27-72

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Steve Notterman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 45 N Gobi Circle 600 Valle Verdi  
Sparks, Nevada 89436 Sparks, Nevada 89436  
 2. LOCATION NW 1/4 SW 1/4 Sec. 20 T. 21 N. N/S R. 21 East Washoe County  
 PERMIT NO. 076-690-39 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	6	6
brown sand stone		6	12	6
light brown clay		12	33	21
multi colored volcanic rock		33	52	19
brown sticky clay		52	175	123
gray sticky clay		175	290	115
weathered granite		290	315	25
brown clay w/ weathered granite		315	345	30
Gray clay with weathered granite		345	375	30
Weathered granite		375	390	15
Light brown clay with weathered granite		390	400	10
Weathered granite		400	480	80
Gray clay with weathered granite		480	483	3
Weathered granite with white clay		483	515	32
Gray & red clay		515	520	5
Gray clay w/ weathered granite	X	520	575	55
Weathered granite	X	575	600	25
Gray clay w/ weathered granite		600	615	15
Brown & gray clay stone		615	620	5

8. WELL CONSTRUCTION  
 Depth Drilled 720 Feet Depth Cased 720 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 600 Feet  
8 1/2 Inches 600 Feet 720 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	720

 Perforations:  
 Type perforation Factory sawed  
 Size perforation 3/32 x 3  
 From 50.0 feet to 540 feet  
 From 680 feet to 700 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 720 feet to 50 feet

-CONTINUED-  
 Date started February 13, 1998  
 Date completed February 24, 1998

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>20+</u>		<u>2 hrs.</u>

9. WATER LEVEL  
 Static water level 290 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, Nevada 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed James Welch  
 By driller performing actual drilling on site or contractor  
 Date March 4, 1998

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37772

1. OWNER Steve Notterman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 45 N. Gobi Circle 600 Valle Verdi  
Sparks, Nevada 89436 Sparks, Nevada 89436  
 2. LOCATION NW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 20 T. 21 N. Q/S R. 21 EAST WASHOE County  
 PERMIT NO. 076-690-39  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Weathered granite	X	620	658	38
Weathered granite w/ red clay		658	662	4
Black & red volcanic rock fractured	X	662	670	8
Black volcanic rock hard		670	675	5
Multi colored volcanic rock fractured	X	675	700	25
Multi colored volcanic rock w/red clay stone	X	700	720	20
T.D. 720'				

8. WELL CONSTRUCTION  
 Depth Drilled 720 Feet Depth Cased 720 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 600 Feet  
8 1/2 Inches 600 Feet 720 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>720</u>

 Perforations:  
 Type perforation Factory sawed  
 Size perforation 3/32 x 3  
 From 500 feet to 540 feet  
 From 680 feet to 700 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 720 feet to 50 feet

Date started February 13, 1998  
 Date completed February 24, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+</u>		<u>2 hrs</u>	

9. WATER LEVEL  
 Static water level 290 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, NEVADA 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed Larry Welch  
 By driller performing actual drilling on site or contractor  
 Date March 4, 1998