Well #2 on Plan

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70872
Permit No.
Basin 83

NOTICE OF INTENT NO. 38028

1. OWNER Truckee River Mobile Home Park
MAILING ADDRESS 1380 Humbolt St.
Reno, NV 89509

ADDRESS AT WELL LOCATION 35 Lockwood Rd.

2. LOCATION SE 1/4 SE 1/4 Sec. 17 T 19N N/S R 21E E Washoe County
PERMIT NO. WaCo#6072 (Issued by Water Resources) | 084-080-33 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other _____

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we perforated the well				
from 90' to the top using a Mills				
Knife. We then pressure grouted				
the well with neat cement using				
tremie pipe from bottom to the top.				
We used approximately 57 sacks of				
neat cement and water at 5.2				
gallons per sack.				
DWS #229				

Date started 2/16/98, 19__
Date completed 2/17/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased 141 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	22.36	.250	0	141

Perforations:
Type perforation Mills Knife
Size perforation _____
From 0 feet to 90 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal Total
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 2-19-98