



Log No. 71901
 Permit No. 103
 Basin 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38826

1. OWNER Michael Walter Construction ADDRESS AT WELL LOCATION 110 Midget Dayton W.
 MAILING ADDRESS 3 Malachite Rd Yerington W. 89447

2. LOCATION SE 1/4 SW 1/4 Sec 9 T. 17 N. R. 22 E Lyon County

PERMIT NO. 19-102-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow Sands		0	3	3
Hard Pan Sands		3	17	14
D4 Sands		17	48	31
Obsidian Sands Clay Seams		48	110	62
Brown Clay		110	163	53
Brown Clay Stratas		163	194	31
Small Sands				
Fractured Volcanic	XXX	194	210	16
Gravels				

8. WELL CONSTRUCTION
 Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)
 From 103/16 Inches To 210 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.518</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>210</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 190 feet to 210 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 55 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 55 feet to 210 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat Dr. Carson City W. 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0041775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Walter
 By driller performing actual drilling on site or contractor
 Date 7-9-98

Date started 4-20, 1998
 Date completed 4-9, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>69</u>	<u>3 HRS</u>

RECEIVED
 98 JUL 14 AM 8:10
 STATE ENGINEERS OFFICE