

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 70945
 Permit No. 70945 62422
 Basin 212

NOTICE OF INTENT NO. 16708

1. OWNER DON GADSBY/GENE CALLAHAN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec 1 T 26 N 59 E CLARK County
 PERMIT NO. 62422 Issued by Water Resources Parcel No. 223-01-000-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, CLAY & GRAVEL		0	20	20
CEMENTED GRAVEL WITH CLAY LENSES		20	130	110
CEMENTED GRAVEL		130	150	20
LIMESTONE		150	260	110
CEMENTED GRAVEL & SANDSTONE		260	310	50
GREY SHALE		310	375	65
CEMENTED GRAVEL		375	400	25
LIMESTONE		400	435	35
GREY SHALE	X	435	480	45
CEMENTED GRAVEL	X	480	510	30
CEMENTED GRAVEL WITH STREAKS OF SHALE	X	510	800	290
QUARTZITE	X	800	850	50

8. WELL CONSTRUCTION
 Depth Drilled 850 Feet Depth Cased 850 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 1/2 Inches 0 Feet 800 Feet
7 7/8 Inches 800 Feet 850 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+2	800
6 5/8	12.9	.188	790	850

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8 X 3 6 ROW
 From 790 feet to 850 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 800 feet

9. WATER LEVEL
 Static water level 463 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 3/1 1998
 Date completed 4/8 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER WELL SERVICES Contractor
 Address 6475 GARY AVE. Contractor
LAS VEGAS, NV 89139

Nevada contractor's license number issued by the State Contractor's Board 22311B
 Nevada driller's license number issued by the Division of Water Resources 1594
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 4/14/98