

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71070
 Permit No. 104
 Basin 104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33306

1. OWNER MATLOEY Electric ADDRESS AT WELL LOCATION CARSON CITY
 MAILING ADDRESS 356 MATLOEY WY
CARSON CITY N.V. INTRA PARK
SAME
 2. LOCATION SW 1/4 NE 1/4 Sec. 20 T. 15 N. R. 20 E. County CARSON
 PERMIT NO. M/10-111 Issued by Water Resources APR 9-01-94 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG RW-12

Material	Water Strata	From	To	Thickness
<u>ON 8-30-97</u>				
<u>I FOUND THE</u>				
<u>WELL TO BE IN</u>				
<u>GOOD CONDITION AFTER</u>				
<u>REMOVING THE TOP</u>				
<u>CAP I THEN</u>				
<u>OVERDRILLED THE CASING</u>				
<u>TO 20' I THEN</u>				
<u>RESSURE GRADED THE</u>				
<u>HOLE FROM 20'</u>				
<u>TO THE SURFACE</u>				

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased N/A Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 1/2" To 0
 Inches 0 Feet 20
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/2"</u>	<u>SCH 40</u>	<u>PVC</u>	<u>0</u>	<u>20</u>

Perforations:
 Type perforation Factory
 Size perforation 1.070
 From 5 feet to 20 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 20' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From N/A feet to N/A feet

9. WATER LEVEL
 Static water level 7' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cold °F Quality N/A

Date started 8-30 1997
 Date completed 8-30 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDERSEN Exploration Drilling Contractor
 Address 1635 Bedford Rd Contractor
RENO N.V. 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-4-97