

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15611

1. OWNER CLARK COUNTY DEPT OF AVIATION ADDRESS AT WELL LOCATION NORTH LAS VEGAS AIRPORT  
 MAILING ADDRESS P.O. Box 11005  
LAS VEGAS NV 89111-1005

2. LOCATION NW 1/4 SW 1/4 Sec 18 T. 20 N. R. 61 E. CLARK County  
 PERMIT NO. 139-18-303-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE CW-1  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	0.3	0.3
GRAVELLY SAND		0.3	1.5	1.2
CLAYEY SILT		1.5	7	5.5
CALICHE		7	8	1
CLAYEY SILT		8	18	10
SILTY CLAY		18	29	11

8. WELL CONSTRUCTION  
 Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 29 Feet  
8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.157</u>	<u>0.67</u>	<u>0.154</u>	<u>0</u>	<u>29</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 0.020  
 From 7 feet to 29 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-2 1/2-7 BENTONITE  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 7 feet to 29 feet

9. WATER LEVEL  
 Static water level 19.60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started DEC 30 1997  
 Date completed DEC 30 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name THOMAS HIGH (CONVERSE CONSULT)  
 Address 731 PIONEER RD. #4  
LAS VEGAS NV 89119  
 Nevada contractor's license number issued by the State Contractor's Board 0034757  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869  
 Signed Thomas High  
 Date 4/10/98