WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71196
Permit No.
Basin T24

NOTICE OF INTENT NO. 31893

1. OWNER JC Penney CO. 1111
MAILING ADDRESS 1111 Stead Blvd. Reno NV 89509

ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ SE ¼ Sec 31 T 21 N/S R 19 E/W Washoe County
PERMIT NO. 90 mo# 273 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG MW #5-DS

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ON 10/1 97 I found the well to be in good condition after opening the top cap I then overdrilled the casing to 27' I then pressure grouted from 27' to the surface. | | | | |

Date started 10/1, 19 97
Date completed 10/1, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 27 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10" Inches | 0 Feet | 27 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | SCH 40 | PVC | 0 | 27 |

Perforations:
Type perforation Factory
Size perforation .020
From 7 feet to 27 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 27'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andersen Exploration Drilling (Contractor)
Address 1635 Beiford Rd (Contractor)
Reno NV 89509
Nevada contractor's license number issued by the State Contractor's Board 54525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/1/97

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627