WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7184
Permit No.
Basin 72A

NOTICE OF INTENT NO. 37775

1. OWNER Ben Sallaberry
MAILING ADDRESS 2520 Riviera
Reno, Nevada 89509

ADDRESS AT WELL LOCATION
11615 Osage

2. LOCATION SE ¼ SE ¼ Sec. 13 T. 20 21 N/S R. 18 EAST County

PERMIT NO. Issued by Water Resources | 86-250-09 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	3	3
Brown clay		3	12	11
Brown clay w/multi colored course sand		12	40	28
Multi colored course sand		40	45	5
Brown clay w/multi colored course sand		45	118	73
Brown sticky clay		118	120	2
Brown clay w/multi colored course sand		120	130	10
Multi colored course sand		130	135	5
Brown clay w/multi colored course sand		135	142	7
Brown clay		142	150	8
Multi colored course sand	X	150	160	10
Brown clay w/multi colored course sand		160	165	5
Multi colored course sand	X	165	220	55
T.D. 220'				

Date started February 10, 19 98
Date completed February 12, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 HRS.

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	220

Perforations:
Type perforation Factory Sawed
Size perforation 3/32x3
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 220 feet to 50 feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. Contractor
Address P.O. Box 60130 Contractor
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed Larry Weber
By driller performing actual drilling on site or contractor
Date Feb 16, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627