

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71610
 Permit No. 107
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21950

1. OWNER M. VIDAL ADDRESS AT WELL LOCATION 25 LINDA WAY
 MAILING ADDRESS 200 ARTIST VIEW DR SMITH VALLEY, NV
WELLINGTON, NV 89444
 2. LOCATION NW 1/4 SE 1/4 Sec. 26 T. 12 S. R. 23 LYON County
 PERMIT NO. 10-111-29 NONE
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Muo

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	20	20
SANDY CLAY w THIN SOLID CLAY BEDS	X	20	90	70
DG SEDIMENT, V AB QTZ + MINOR BROWN CLAYS	X	90	160	70
JUST TOUCHED THE TOP OF THE LAKE BED.				
WATER HAS A SLIGHT H ₂ S SMELL.				
TASTES GOOD				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 160 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>160</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3x 3/32
 From 120 feet to 160 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 160 feet

Date started 2/16 1998
 Date completed 2/19 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>100+</u>	<u>-</u>	<u>3</u>

9. WATER LEVEL
 Static water level: 3 feet below land surface
 Artesian flow No - Close G.P.M. P.S.I.
 Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CREEK RD Contractor
CARSON CITY, NEVADA 89704
 Nevada contractor's license number issued by the State Contractor's Board: 13697A
 Nevada driller's license number issued by the Division of Water Resources the on-site driller: 1476
 Signed Joe Feisek
 Date 2/23/98