WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7168
Permit No. 108
Basin

NOTICE OF INTENT NO 37757

1. OWNER O-N Ranch
MAILING ADDRESS P.O.Box 1576
Sparks Nv 89432

ADDRESS AT WELL LOCATION
126 Pete Hendricks RD
Yerington, NV 89447

2. LOCATION NE ¼ NE ¼ Sec. 36 T 13 N/S R 26 East Lyon County

PERMIT NO. (Issued by Water Resources) Parcel No. 14-551-03 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	12	12
multi colored large				
gravels & course				
sand	X	12	105	93
Brown Clay		105	108	3
Multi colard gravel				
& course sand		108	130	22
Brown clay with				
multi colored				
gravels & sand	X	130	170	40
Brown sticky clay		170	180	10
multi colored				
gravles & course sand	X	180	240	60

T.D. 240'

RECEIVED 98 MAY 29 AM 11:31 STATE ENGINEER'S OFFICE

Date started May 20, 1998
Date completed may 22, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 HRS

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 5/8	0	240

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1 1/2	240

Perforations:
Type perforation Johson screen
Size perforation .050
From 140 feet to 60 feet
From feet to feet
From 200 feet to 220 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 240 feet to 100 feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O.Box 60130 (Contractor)
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date May 28, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627