



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35064

1. OWNER Dan + Val Brady ADDRESS AT WELL LOCATION Desert Shadows #9 Whigham Dr., Fernley, NV.
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec. 25 T. 20 N/S R. 24 E. Lyon County _____
 PERMIT NO. 21-162-18 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mpel

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Boulder Clay</u>		<u>0</u>	<u>11</u>	
<u>Boulder Clay, Coarse</u>		<u>11</u>	<u>28</u>	
<u>Small Gravel</u>		<u>28</u>	<u>126</u>	
<u>Solidified Gravel (Same Clay)</u>		<u>126</u>	<u>342</u>	
<u>Coarse Gravel</u>		<u>342</u>	<u>400</u>	

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 100 Feet
8 3/4 Inches 100 Feet 400 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>400</u>

Perforations:
 Type perforation Mill Perf
 Size perforation 1/8" x 3" 6 Rows
 From 360 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 80+ Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 253 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 60 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jason Diney, Inc Contractor
 Address P.O. Box 8942 Contractor
89 NV
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1874
 Signed: Jason Diney
 By driller performing actual drilling on site or contractor
 Date 6/25/98

Date started 6/18, 19____
 Date completed 6/22/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>6 pm</u>	<u>2 1/4 hrs</u>

RECEIVED
 98 JUL 23 AM 10:00
 STATE ENGINEERS OFFICE

