WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.240

OFFICE USE ONLY
Log No. 72264
Permit No.
Basin 105

NOTICE OF INTENT NO. 28165

1. OWNER Tony Avenzino
MAILING ADDRESS 1284 Larrate Ct.
Minden NV 89410

ADDRESS AT WELL LOCATION 1371 Buckwheat Cir
Gardnerville NV

2. LOCATION SE ¼ SE ¼ Sec. 36 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23-482-270 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay and Gravels		0	3	3
Hard Pan		3	9	6
Coarse Gravels Small Sands		9	79	70
Brown Clay		79	143	64
Small Obsidian Sands and Clay Seams (Brown)		143	230	87
Brown Clay		230	250	20
Fractured obsidian Gravels W/water Tight formation Cemented Gravels	NX	250	300	50

Date started 5-19, 1998
Date completed 5-22, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	55	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 3/4	0	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. (Contractor)
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Beck
By driller performing actual drilling on site or contractor
Date 5-22-98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627