


WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 72353
Permit No. 61
Basin 61

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39531

1. OWNER BARRICK GOLDSTRIKE MINES ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE SITE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89803

2. LOCATION NE 1/4 SW 33 T. 36 N/S R. 50 E EUREKA County
PERMIT NO. N/A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| ALLUVIUM | | 0 | 160 | 160 |
| SAND | | 160 | 280 | 120 |
| SAND & BROWN CLAY | | 280 | 380 | 100 |
| BROWN CLAY | | 380 | 400 | 20 |
| BROWN CLAY & SAND | | 400 | 490 | 90 |
| GRAY SAND | | 490 | 510 | 20 |
| BROWN SAND | | 510 | 580 | 70 |
| TAN CLAY | | 580 | 610 | 30 |
| GRAYISH BLACK ROCK | | 610 | 760 | 150 |
| BLACK ROCK | | 760 | 820 | 60 |

N 40.954351
W 116.329757 NAD27

8. WELL CONSTRUCTION
Depth Drilled 820 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)
From To
20.5 Inches 0 Feet 22 Feet
17.875 Inches 22 Feet 820 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 13.375 | 68.75 | .500 | 0 | 22 |
| 2 | 5.02 | .218 | +2 | 780 |
| 1.25 | 3.00 | .191 | +2 | 360 |

Perforations: SLOTTED
Type perforation
Size perforation 0.125
From 2": 800 feet to 780 feet
From 1.25": 380 feet to 360 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 330 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No 2": 403 - 820
From 1.25" feet to 25" feet 330 - 750 feet

9. WATER LEVEL
Static water level 2:140, 1.25:179 feet below land surface
Artesian flow NONE G.P.M. P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started JULY 30 19 98
Date completed AUGUST 3 19 98

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Name LANG EXPLORATORY DRILLING Contractor
Address P.O. BOX 5279 Contractor
ELKO, NV 89802
Nevada contractor's license number 0021976
issued by the State Contractor's Board
Nevada driller's license number issued by the 2047
Division of Water Resources, the on-site driller
Signed Richard VanHousen
By driller performing actual drilling on site or contractor
Date AUGUST 3, 1998

RECEIVED
98 AUG 14 AM 11:28
STATE ENGINEERS OFFICE