WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72369
Permit No.
Basin 212

NOTICE OF INTENT NO. 16664

1. OWNER Agra Earth Enviromental
MAILING ADDRESS 4205 W. Tompkins
Las Vegas, NV 89103
ADDRESS AT WELL LOCATION 1250 W. Sunset

2. LOCATION NW ¼ SE ¼ Sec. 4 T. 22 N/S R. 62 E. Clark County
PERMIT NO. DW-1090 (Issued by Water Resources) 178-03-210-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill, gravel, boulders		1	14	14
Gravel, boulders		14	16	2
Med. hard rock		16	18	2
Brown clay		18	20	2
Med. hard rock w/salt & pepper material		20	40	20
Brown clay mixed w/med. hard formation		40	50	10
Med hard salt & pepper colors w/brown clay formation		50	60	10

Date started August 8, 19 98
Date completed August 18, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
260	12	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12 1/4	1	60

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	1	58

Perforations:
Type perforation mill
Size perforation 1/8 x 2 1/2- 8 rows
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1 feet to 58 feet

9. WATER LEVEL
Static water level 20.2 feet below land surface
Artesian flow 75 G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck Street (Contractor)
Las Vegas, NV 89118
Nevada contractor's license number 4286A issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed Richard Thompson (By driller performing actual drilling on site or contractor)
Date August 24, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627