



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57886

1. OWNER WILLIAM & PHYLLIS HEARN ADDRESS AT WELL LOCATION 11580 Campo Rico Lane  
 MAILING ADDRESS 311 - 5th Street Spark, Nevada 89436  
 2. LOCATION SE 1/4 SE 1/4 Sec. 14 T 21N N/S R. 20 E Washoe County Spanish Springs  
 PERMIT NO. 076-360-70 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Sandy brown clay		1	4	3
Brown fine sand		4	9	5
Sand, brown clay		9	31	22
Decomposed granite sands		31	42	11
Sandy brown clays		42	96	54
Decomposed granite sands		96	101	5
Sandy brown clays		101	135	34
Soft zone, med coarse sands	X	135	146	11
Brown clay		146	161	15
Medium coarse rusty decomposed granite sands	X	161	176	15

8. WELL CONSTRUCTION  
 Depth Drilled 176 Feet Depth Cased 176 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 176 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	176

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 129 feet to 169 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 176 feet

9. WATER LEVEL  
 Static water level 105 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature cold °F Quality clear

Date started 9-14-98, 19\_\_\_\_  
 Date completed 9-15-98, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board  
 Nevada driller's license number 923 issued by the  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date September 19, 1998