

OFFICE USE ONLY
 Log No. 72709
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 36055

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WINGFIELD SPRINGS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7755 SPANISH SPRINGS ROAD HEALTH DEPT PERMIT 006194
SPARKS NEVADA 89436
 2. LOCATION NW 1/4 SE 1/4 Sec. 13 T. 20 N/S R. 20 E WASHOE County
 PERMIT NO. W-500 Issued by Water Resources 522-080-01 Parcel No. RED HAWK GOLF COURSE-WINGFIELD SPRINGS Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, BROKEN ROCK		0	45	45
COBBLES, BOULDERS		45	55	10
CLAY, BROKEN ROCK, COBBLES		55	105	50
BROWN STICKY CLAY		105	162	57
ROCK BROWN CLAY		162	175	13
BEDROCK GREY/BROWN		175	188	13
RED/BROWN CLAY		188	238	50
GREY CLAY & SILT		238	260	32
SAND, BLACK BASALT		260	270	10
BLACK, GREY BASALT		270	310	40
CLAY, BROKEN ROCK		310	395	85
BROWN/GREY CLAY		395	419	24
BLACK ROCK, SAND, CLAY		419	498	79
GREY/GREEN CLAY, SAND		498	586	88
WHITE/GREY CLAY		586	640	54

8. WELL CONSTRUCTION
 Depth Drilled 640 Feet Depth Cased NONE Feet
 HOLE DIAMETER (BIT SIZE)
12 3/4 Inches From 0 Feet To 640 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NONE				

Perforations:
 Type perforation NONE
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 640
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality FAIR

HOLE ABANDON
 18 YARDS³ WAS PUMPED FROM SURFACE VIA TREMI PIPE FROM THE BOTTOM OF THE HOLE TO THE SURFACE
 TO ABANDON LOG # 72708

Date started JUNE 26, 1998
 Date completed AUGUST 17, 1998

DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SARGENT IRRIGATION COMPANY Contractor
 Address 9955 NORTH VIRGINIA STREET
RENO NEVADA 89506
 Nevada contractor's license number issued by the State Contractor's Board 21246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1789
 Signed _____
 By driller performing actual drilling on site or contractor
 Date AUGUST 19, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			