

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 73003  
 Permit No. 61746  
 Basin.         

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34345

1. OWNER MONTY LOYD ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6100 CURRY ROAD  
FALLON NV 89406

2. LOCATION NE 1/4 SW 1/4 Sec 7 T. 34 N/S R. 29 E PERSHING County  
 PERMIT NO. #61746 Parcel No. \_\_\_\_\_ Subdivision Name BLACK ROCK WELL

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
We scooped well until clean IT SHOWED THE CASING WAS INTACT TO BOTTOM AT 450 FT. I CANNOT VERIFY A SURFACE SEAL OR PERFORATION SIZE OR TYPE OR DEPTH				
We waited with the log UNTIL THEY TEST PUMPED THE WELL				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 450 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>		<u>.225</u>	<u>0</u>	<u>450</u>

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 240 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.0 °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name M-NINCH DRILLING Contractor  
 Address PO Box 585 Contractor  
WVMA, NV. 89445

Nevada contractor's license number #5437  
 issued by the State Contractor's Board

Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller 1712

Signed Mike M. Ninch  
 By driller performing actual drilling on site or contractor

Date 10-28-98

Date started 4-17, 1998  
 Date completed 5-1, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>150</u>	<u>250</u>	<u>3</u>

PUMP SETTING OF 380' WAS USED FOR THE TEST

RECEIVED  
 98 NOV -2 AM 10:25  
 STATE ENGINEER'S OFFICE