WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73041
Permit No.
Basin 162

NOTICE OF INTENT NO. 15254

1. OWNER TERRY, WILL
MAILING ADDRESS HWY 160 & SIMKINS RD
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION HWY 160 & SIMKINS RD

2. LOCATION NW 1/4 NE 1/4 Sec. 27 T 19S N/S R 53E E NYE County
PERMIT NO. W2084 (Issued by Water Resources) 27-191-06 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BACK FILLED WELL FROM				
1040 TO 420 FT WITH				
GRAVEL PLACED A 5 FT				
BENTONITE SEAL EVERY				
100 FT FROM 420 TO 100				
FT PUMPED WYOMING				
BENTONITE HOLE PLUG.				
FROM 100 FT TO SURFACE				
PLUGED WITH CONCRETE				
GROUT.				

Date started 12/22/98 , 19__
Date completed 12/29/98 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation RIPPED CASING WITH MILLS KNIFE
Size perforation
From 50 feet to 420 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 030880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on-site or contractor)
Date 12/31/98

USE ADDITIONAL SHEETS IF NECESSARY