

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18384

1. OWNER Norman Neiswonger ADDRESS AT WELL LOCATION 3290 S. Winchester Ave.
MAILING ADDRESS _____

2. LOCATION SE 1/4 NW 1/4 Sec. 32 T. 20-S. N/S R. 53 E. Nye County Nye
PERMIT NO. 40-531-15 Calvada Valley Ut. 5, Blk. 10, Lot 15
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Gray clay		4	25	21
Green clay		25	36	11
Gray clay/caliche		36	58	22
Brown clay	x	58	82	24
Brown clay/caliche		82	108	26
Brown clay	x	108	140	32

8. WELL CONSTRUCTION

Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12</u> Inches	<u>0</u> Feet <u>140</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
Type perforation Torch Cut
Size perforation 1/4" width 8" long
From 100 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 6.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC Contractor
Address P.O. Box 56 Contractor
Pahrump, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812

Signed [Signature]
By driller performing actual drilling on site or contractor
Date November 6, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>4</u>	<u>1/2</u>