

OFFICE USE ONLY
 Log No. 73100
 Permit No. 103
 Basin. 103
 NOTICE OF INTENT NO. 38896

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Cathy Selava ADDRESS AT WELL LOCATION 170 James
 MAILING ADDRESS 170 Box 951 Dayton Dayton NV
NV 89423
 2. LOCATION SW 1/4 SE 1/4 Sec 16 T 16 S R 22 E Lyon County
 PERMIT NO. 19-471-04 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RYC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Coarse Sands</u>		<u>6</u>	<u>16</u>	<u>10</u>
<u>Brown Clay</u>		<u>16</u>	<u>43</u>	<u>27</u>
<u>Coarse Brown Sands Small</u>		<u>43</u>	<u>110</u>	<u>67</u>
<u>Gray Clay</u>		<u>110</u>	<u>121</u>	<u>11</u>
<u>Fractured obsidian Sands and small Sands</u>	<u>XX</u>	<u>121</u>	<u>160</u>	<u>39</u>

DEPOSITED
 10/10/10
 10/10/10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 160 Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>15.34</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

 Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 140 feet to 160 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 55 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 160 feet

Date started 10-10, 1998
 Date completed 10-11, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>	<u>30</u>	<u>2 Hrs</u>

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow 30+ G.P.M. 30+ P.S.I.
 Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 K. J. K. Dr. Contractor
Carson City NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Deel
 By driller performing actual drilling on site or contractor
 Date 10-23-98