

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. **73105**
 Permit No. _____
 Basin **162**

NOTICE OF INTENT NO. **18098**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **Anthony and Linda Demeo** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **2680 Bailey Ct.** **2680 Bailey Ct.**
Pahrump, NV 89048

2. LOCATION **NW 1/4 NE 1/4 Sec. 12 T 21S** N/S **R 53E** E **Nye** County
 PERMIT NO. **44-521-42** **Pahrump** Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See next line		0	36	36
brown sandy loam and small calache strings				
See next line		36	48	12
brown sandy loam and calache strings				
light brown clay		48	50	2
light brown clay	x	50	79	29
light brown calache	x	79	103	24
light brown clay	x	103	140	37

8. WELL CONSTRUCTION

Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
11	0	140		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **sawcut**
 Size perforation **.188**

From	To	Feet	Feet
100	140		

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **140** feet

9. WATER LEVEL

Static water level **50** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

Date started **12/29/98**, 19____
 Date completed **12/29/98**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	5	na	.50

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *Larry Strickland*
 By driller performing actual drilling on-site or contractor
 Date **1-10-99**

