

OFFICE USE ONLY
 Log No. 73128
 Permit No. 21206
 Basin. 203

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34407

1. OWNER Bill McInnis
 MAILING ADDRESS 6520 No. Tenaya Way
Las Vegas, NV 89131
 ADDRESS AT WELL LOCATION ZW Ranch
7 Mi. N. of Caliente NV
Caliente Nevada
 2. LOCATION SE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec. 2 T. 3 N. 67 E. Lincoln County
 PERMIT NO. 21206 Issued by Water Resources Parcel No. 013-03-021 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	43	43
Blue Gray Clay /sulfides	60	43	97	54
Boulders and gravel		97	101	4
Brown Conglomerate		101	203	102
Brown Sand	xx	203	210	107
Sandy Claystone	x	210	400	190
Cemented 100' because of $\frac{1}{2}$ Mi. Creek rule and encountered stinking water between 60' and 100'. Water below 100' has no bad odor. Well required approx. 20 yards of cement due to caving area between 60 and 100'				

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
30 Inches 0 Feet 16 Feet
17 $\frac{1}{2}$ Inches 16 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>		<u>.250</u>	<u>-1</u>	<u>400</u>

 Perforations: Mill Slot
 Type perforation _____
 Size perforation 1/8" x 3"
 From 101 feet to 119 feet
 From 201 feet to 239 feet
 From 361 feet to 379 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100' feet to 400' feet

Date started 10-8-97, 19_____
 Date completed 7-30-98, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	250	400	15

9. WATER LEVEL
 Static water level: 22 feet below land surface
 Artesian flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MILLER & SONS DRILLING CO. Contractor
 Address P.O. Box 8056
reno, NV 89507 Contractor
 Nevada contractor's license number 0037915
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1418
 Division of Water Resources, the on-site driller
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 8-25-98