WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73188
Permit No. 64237
Basin 143

NOTICE OF INTENT NO. 17553

1. OWNER Nellis AFB
MAILING ADDRESS Gold Flat
Beatty NV

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 6 M/S R 48 E SE County
PERMIT NO. APP 64237 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse sand / Clay		0	17	17'
rock / Clay		17	27	10'
rock		27	37	
rock		37	47	
rock		47	57	
rock / Clay		60	67	
rock / Clay		67	77	
rock		77	87	
Clay Rock		87	97	
rock		97	107	
Rock		107	117	
rock		117	127	
rock		127	137	
rock		137	147	
rock		147	157	
rock		157	167	
Chipped rock		167	177	
Chipped rock		177	187	
Chipped rock		187	197	
rock		197	207	
Smooth rock Chipped clay		207	217	
Chipped rock Clay		217	227	
Rock Clay		227	237	
rock		237	247	
rock		247	257	
rock Clay Bubbles		257	267	
Chipped rock		267	277	
Sample rock		277	287	
rock		287	297	10'

Date started 12 Sept, 1998
Date completed 5 OCT, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

11-23-98

8. WELL CONSTRUCTION
Depth Drilled 410 Feet Depth Cased 410 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17 Inches		0 Feet	10 Feet
9 7/8 Inches		10 Feet	410 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.322	0	110
6		.322	170	290
6		.322	310	330
		.322	390	410

Perforations:
Type perforation Slotted
Size perforation 0.25
From 110 feet to 170 feet
From 290 feet to 310 feet
From 330 feet to 390 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55' feet to 410 feet

9. WATER LEVEL
Static water level 242 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BENITO VARANTO
Address 6554 MERMAID Circle (Contractor)
Las Vegas NV 89108 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1923
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627