

Revised Report

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 73198
Permit No. 99
Basin.

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34521

1. OWNER Nathan & Yvonne Brown ADDRESS AT WELL LOCATION 400 Appaloosa Circle
MAILING ADDRESS 1473 So. Arlington Reno, NV 89509 Reno, NV 89506
2. LOCATION SW 1/4 SW 1/4 Sec. 4 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. 006195 078-221-15 Rancho Haven
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other.
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Test, Stock.
5. WELL TYPE: Cable, Rotary, RVC, Air, Other.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Topsoil		0	3	
Brown Sandy Clay		3	14	
Brown Clay		14	68	
Brown Sandy Clay		68	160	
Orange Clay		160	190	
Brown Clay		190	205	
Orange Clay		205	280	
DG White		280	345	

8. WELL CONSTRUCTION
Depth Drilled 345 Feet Depth Cased 345 Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 0 Feet 345 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 .225 0 345

Perforations:
Type perforation Factory
Size perforation 1/8"
From 325 feet to 345 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 54' Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 54 feet

9. WATER LEVEL
Static water level .5 feet below land surface
Artesian flow .5 G.P.M. P.S.I.
Water temperature cold °F Quality

Date started 9-25 19 98
Date completed 9-29 19 98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	10		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Turner Drilling & Pump Contractor
Address 472-205 Johnstonville Rd. Susanville, CA 96130 Contractor
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037
Signed [Signature] By driller performing actual drilling on site or contractor
Date 10-6-98

RECEIVED
99 JAN 14 AM 9 58
STATE ENGINEERS OFFICE