

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39668

1. OWNER GITA GOLD ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1525 E. Newlands Drive #100 OLING WOODSE MINE MW 04
Fernley Nevada 89408
 2. LOCATION NW 1/4 NE 1/4 Sec 29 T. 21 N. R. 23 E. Washoe County
 PERMIT NO. MO 1093 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Pulled Pump riser</u>	<u>Bentonite</u>	<u>730</u>	<u>20</u>	<u>710</u>
<u>Knocked out bottom</u>	<u>cement</u>	<u>20</u>	<u>surface</u>	<u>20</u>
<u>of well screen</u>				
<u>pumped bentonite</u>				
<u>grout to 20' cement</u>				
<u>to surface</u>				

8. WELL CONSTRUCTION
 Depth Drilled 730 Feet Depth Cased 728 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
14 3/4 Inches 0 Feet 11 Feet
10 Inches 11 Feet 730 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 1/2</u>			<u>0</u>	<u>11</u>
<u>5</u>			<u>+2</u>	<u>728</u>

Perforations:
 Type perforation slotted
 Size perforation 0.20
 From 6.78 feet to 728 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 730 to 20' Bentonite Neat Cement
 Placement Method: Pumped 20' surface Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 9-2 1998
 Date completed 9-28 1998

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>N/A</u>	

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Harris Exploration Drilling Contractor
 Address 260 11 South Orange Street Contractor
Escondido Ca 92025
 Nevada contractor's license number CO 26000
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the M-2114
 Division of Water Resources, the on-site driller.
 Signed Peter Harris
 By driller performing actual drilling on site or contractor
 Date Oct 1, 1998