WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73209
Permit No. 99
Basin

NOTICE OF INTENT NO. 34519

1. OWNER Keever Construction
MAILING ADDRESS 1700 Whitewood
Sparks, NV 89434

ADDRESS AT WELL LOCATION 16200 Fetlock
Reno, NV 89503

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. 006173 (Issued by Water Resources) 078-231-07 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay & DG		0	30	
Tan Clay & DG		30	40	
Red Clay		40	80	
Brown Clay & Black Cinders		80	90	
Brown Clay, Red Cinders & Black Gravel		90	105	
Green Clay		105	115	
Yellow Clay, DG & Fine Sand		115	130	
Grey Clay & DG		130	160	
DG		160	230	
Broken Granite		230	240	
Broken Granite & Gravel		240	266	

Date started 9-22, 19 98
Date completed 9-25, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		.5

8. WELL CONSTRUCTION
Depth Drilled 266 Feet Depth Cased 266 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	266 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.250	0	266

Perforations:
Type perforation Factory
Size perforation 1/8"
From 246 feet to 266 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From 0 feet to 53 feet

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Turner Drilling & Pump (Contractor)
Address 472-205 Johnstonville Rd. (Contractor)
Susanville, CA 96130
Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2038
Signed Frank Turner (By driller performing actual drilling on site or contractor)
Date 10-6-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627