

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16

1. OWNER Wasco County Utility Div ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P.O. Box 11130 Reno NV 89520

2. LOCATION SW 1/4 SW 1/4 Sec 11 T. 20N N/S R. 24 E. Wasco County _____
PERMIT NO. ADW 20-113-06 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and Fine Gravel		0	10	10
Clay Silt + Sand		10	73	63
Clay		73	80	7
Clay + Sand	✓	80	108	28
Sand + Fine Gravel	✓	108	120	12
Clay Silt Sand + Fine Gravel	✓	120	130	10
Clay		130	136	6
Clay Silt Sand + Fine Gravel	✓	136	150	14

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Air Lift	30	TOTAL	4

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 150
5 3/4 Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation well screen
Size perforation 80
From 120 feet to 150 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 102 feet to 150 feet

9. WATER LEVEL
Static water level 49.98 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NV Drilling Contractor
Address 75 Lewers Ln. Rel Carson City, NV 89704 Contractor
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10-30-98

Date started Oct 6 1998
Date completed Oct 8 1998



12