well #9

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 73297
Permit No.
Basin 76

NOTICE OF INTENT NO.

1. OWNER Washoe County Utility Div
MAILING ADDRESS PO Box 11130 Reno NV 89520
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 5 T 20 N N/S R 25 E Washoe County
PERMIT NO. (Issued by Water Resources) Apn 84-230-10 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 20 | 20 |
| Clay silt Sand | ✓ | 20 | 160 | 140 |
| Sand Gravel | ✓ | 160 | 189 | 29 |
| Clay | ✓ | 189 | 191 | 2 |

Date started Sept 28, 1998
Date completed Sept 30, 1998

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Air Lift | 60 | Total | 3 Hours |

8. WELL CONSTRUCTION
Depth Drilled 191 Feet Depth Cased 191 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 3/4 Inches | 0 Feet | 191 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4" | | 188 | +1 | 161 |

Perforations:
Type perforation Wire Wrap Well Screen
Size perforation .50
From 161 feet to 191 feet.
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 152'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 165 feet to 190 feet

9. WATER LEVEL
Static water level 121.80 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NV Drilling (Contractor)
Address 75 Lewers Cr. Rd (Contractor)
Carson City NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-30-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627