well # 11

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 132919
Permit No.
Basin 716

NOTICE OF INTENT NO.

1. OWNER Washoe County Utility Div.
MAILING ADDRESS PO Box 11130 Reno NV 89520
ADDRESS AT WELL LOCATION # 11

2. LOCATION SW ¼ SW ¼ Sec. 01 T 20 N N/S R 24 E Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 84-230-02 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
AEOLIAN SILT + SAND		0	20	20
SAND + GRAVEL		20	30	10
SANDY CLAY		30	70	40
SAND		70	80	10
SILT, SAND, CLAY		80	90	10
SILTY CLAY		90	140	50
CLAY, SAND, GRAVEL		140	175	35
SANDY CLAY		175	180	5

RECEIVED 98 DEC 29 AM 9:57 STATE ENGINEERS OFFICE

Date started Dec 2, 1998
Date completed Dec 4, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	total	4 Hours

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		188	+2	150

Perforations:
Type perforation 80 Slot Wire Screen
Size perforation
From 150 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 130
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 130 feet to 180 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature °F. Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NV Drilling Inc. Contractor
Address 75 Iviners Cr Rd Carson City NV 89704 Contractor
Nevada contractor's license number issued by the State Contractor's Board 13697-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-08-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627