

Well # 10A

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 73302
Permit No. 76
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO.

1. OWNER Washoe County Utility Div ADDRESS AT WELL LOCATION #10
MAILING ADDRESS PO Box 11130 Reno NV 89520

2. LOCATION SE 1/4 SE 1/4 Sec 36 T. 21 N. N/S R. 24 E. Washoe County
PERMIT NO. 29-150-33 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Work Strata	From	To	Thick-ness
Sand		0	7	7
Clay Silt Sand		7	50	43
Clay Sand		50	70	20
Sand Blue Clay		70	97	27
Silt Sand & Gravel		97	115	18
Silt Sand Gravel Cabbles		115	123	8
Clay + Sand		123	175	52
gravel with minor sand and silt		175	200	25

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet
HOLE DIAMETER (BIT SIZE)
From 8 3/4 Inches To 0 Feet 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		158	+2	170

Perforations:
Type perforation 80 Silt Wire Screen
Size perforation
From 170 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 150 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 150 feet to 200 feet

9. WATER LEVEL
Static water level ~ 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.4 °F Quality

Date started Nov 16, 1998
Date completed Nov 18, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	30-50	total	4 Hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NV Drilling Inc. Contractor
Address 75 Leavers Ct. Red Carson City, NV Contractor 89704
Nevada contractor's license number issued by the State Contractor's Board 13697-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [Signature] By driller performing actual drilling on site or contractor
Date 12/8/98

RECEIVED
98 DEC 29 AM 9:58
STATE ENGINEERING OFFICE