

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18005

1. OWNER Wolfgang Lettow ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 5951 4390 W. Gerald St  
Pahrump, NV 89041 Pahrump, NV 89048  
 2. LOCATION SE 1/4 NW 1/4 Sec. 23 T. 20S N/S R. 52E E Nye County  
 PERMIT NO. 28-821-03 28-821-08 Charleston Park Ranchos U8/L44  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Strips white/grey clay		4	36	32
Brown clay		36	58	22
Grey clay	x	58	94	36
Brown clay	x	94	132	38
White clay		132	136	4
Grey clay		136	140	4

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches \_\_\_\_\_ Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.118	0	140

Perforations:  
 Type perforation torch cut  
 Size perforation 1/4" wide x 8" long  
 From 1.00 feet to 1.40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5.0'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5.0 feet to 1.40 feet

9. WATER LEVEL  
 Static water level: 5.6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Well Drilling Contractor  
 Address 1060 W. Basin Rd Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number 7484  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date 1-27-99

Date started 1-23-99, 19\_\_\_\_  
 Date completed 1-24-99, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>2.0</u>	<u>-0-</u>	<u>15 min</u>

