

Log No. 73365
 Permit No. 84
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39794

1. OWNER VIRGIL PIMENTAL ADDRESS AT WELL LOCATION PEAK ROAD
 MAILING ADDRESS P.O. BOX 21792 RENO, NV 89510
EL CAJON, CA 92021
 2. LOCATION SE 1/4 NW 1/4 Sec. 1 T. 22 N/S R. 20 EAST WASHOE County Washoe
 PERMIT NO. 076-241-14 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN D.G.		0	6	6
DECOMPOSED GRANITE		6	15	9
LIT. BROWN CLAY W/DECOMPOSED GRANITE		15	18	3
MULTI COLORED GRANITE W/ FRACTURED HARD		18	50	32
SALT & PEPPERED GRANITE		50	275	225
MULTI COLORED GRANITE		275	300	25
FRACTURED SALT & PEPPER GRANITE HARD		300	320	20
FRACTURED SALT & PEPPER GRANITE		320	340	20
MULTI COLORED GRANITE FRACTURED		340	425	85
T.D. 425 feet				

8. WELL CONSTRUCTION
 Depth Drilled 425 Feet Depth Cased 425 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 50 Feet
10 5/8 Inches
 From 50 Feet To 425 Feet
8 3/4 Inches
 From Feet To Feet
 Inches
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+1 1/2	425

Perforations:
 Type perforation FACILITY SAMPLE
 Size perforation 3/32
 From 405 feet to 425 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 80 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 425 feet to 80 feet

9. WATER LEVEL
 Static water level 320 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature COLD °F Quality

Date started SEPTEMBER 11, 1998
 Date completed SEPTEMBER 17, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>	<u> </u>	<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE, INC. Contractor
 Address P.O. BOX 60130 Contractor
RENO, NV 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed Terry Welch
 By driller performing actual drilling on site or contractor
 Date SEP 21, 1998