



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39793

1. OWNER LESTER WITHERS ADDRESS AT WELL LOCATION 5100 GRAYVAN ROAD
 MAILING ADDRESS 5100 GRAYVAN ROAD
RENO, NV 89510 RENO, NV 89510
 2. LOCATION NW 1/4 NW 1/4 Sec 30 T 23 N/S R. 21 E. AST WASHOE County
 PERMIT NO. 076-350-09 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN FINE SAND		0	3	3
BROWN CLAY W/MULTI				
COLORED GRAVELS		3	25	22
BROWN STICKY CLAY		25	55	30
BROWN CLAY W/MULTI				
COLORED FINE & COARSE SAND		55	95	40
MULTI COLORED SAND & GRAVELS		95	110	15
BROWN & WHITE CLAY W/MULTI COLORED				
COARSE SAND		110	130	20
MULTI COLORED COARSE SAND & GRAVELS	x	130	160	30
TD 160'				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 160 Feet
 ..Inches.....Feet.....Feet
 ..Inches.....Feet.....Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	17.0	.225	+1 1/2	160

 Perforations:
 Type perforation FACTORY SAWED
 Size perforation 3/32x3
 From 1.40 feet to 1.60 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
xvol clay II
 Gravel Packed: Yes No
 From 160 feet to 50 feet

Date started SEPTEMBER 8, 1998
 Date completed SEPTEMBER 11, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2HRS.</u>

9. WATER LEVEL
 Static water level 20' feet below land surface
 Artesian flow.....G.P.M.....P.S.I.
 Water temperature cold °F Quality.....
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. PUMP & WELL SERVICE, INC. Contractor
 Address P.O. BOX 60130 Contractor
RENO, NV 89506 Contractor
 Nevada contractor's license number 35387A issued by the State Contractor's Board
 Nevada driller's license number issued by the 2066 Division of Water Resources, the on-site driller
 Signed Lester Withers
 By driller performing actual drilling on site or contractor
 Date Sept 14/1998