WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73408
Permit No.
Basin 87

NOTICE OF INTENT NO. 38047

1. OWNER Steve Damonte
MAILING ADDRESS 12276 Sage Hill Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION
12276 Sage Hill Rd.

2. LOCATION SE 1/4 SE 1/4 Sec. 21 T 18N N/S R 20E E Washoe County
PERMIT NO. WaCo#6019 R328 (Issued by Water Resources) | 016-400-74 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay w/coarse sand		0	10	10
Volcanic rock w/coarse sand	x	10	35	~~18~~ 25

See R-328
Mike Anderson
ok'd 22' well
10' real, 10' perf.
on 10/5/98

Date started 10/5/98, 19__
Date completed 10/6/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	35 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	35

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 25 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 15
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 15 feet to 35 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 82 °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 10-10-98