WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73409 73409
Permit No.
Basin 11

NOTICE OF INTENT NO. 7997

1. OWNER NASH & LYNN HERRERA
MAILING ADDRESS 8175 STINSON #16
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION
3910 CELESTE CT. WINNEMUCCA, NEVADA 89445

2. LOCATION NW 1/4 ____ 1/4 Sec. 24 T 35 N/S R 38 E HUMBOLDT County
PERMIT NO. ____ Issued by Water Resources | 14-111-21 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	6	6
SAND & GRAVEL		6	32	26
CLAY		32	46	14
LARGE SAND & GRAVEL		46	98	52
See next line		98	126	28
SAND & GRAVEL W/S CLAY STRINGERS				

Date started 10/12/98, 19__
Date completed 10/12/98, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 126 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-7/8	Inches	0 Feet	126 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1	120

Perforations:
Type perforation SINGLE ROW MILL SLOT
Size perforation 1/8 X 3
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 126 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019
Signed [signature] By driller performing actual drilling on-site or contractor
Date 10-19-98