WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73419
Permit No.
Basin 110C

NOTICE OF INTENT No. 38285

1. OWNER U.S. Army Depot Hawthorne
MAILING ADDRESS Dist Hwy 95
Hawthorne - Nev 89415
ADDRESS AT WELL LOCATION Bldg. 103-6
Army Depot Hawthorne, Nev

2. LOCATION NE ¼ NW ¼ Sec. 10 T. 8 N/S R. 30 E. Mineral County
PERMIT NO. NONE Issued by Water Resources
6-300-01 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Back fill (clean soil) sand		0	13	13
med sand Black (oil)		13	17	4
gray-olive silty clay		17	19	2
med to coarse sand Black to gray		19	25	6
silt to fine sand grayish olive		25	35	10
med to coarse sand light olive		35	50	15
fine sand grayish-olive dusky yellow layers		50	53	3

AJW 103-6-5

Date started May 19, 1998
Date completed May 19, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO WATER		

8. WELL CONSTRUCTION
Depth Drilled 53 Feet Depth Cased 52 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8¼ Inches	0 Feet	53 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch. 80	0	17

Perforations:
Type perforation slot
Size perforation .020
From 17 feet to 53 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 53 feet

9. WATER LEVEL
Static water level NONE feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Christensen (Contractor)
Address 11001 Etiwanda Ave (Contractor)
Fontana - CA 92337
Nevada contractor's license number issued by the State Contractor's Board 0019101
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1468
Signed Steve Johnson
By driller performing actual drilling on site or contractor
Date 5/23/98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627

AIW - 103-6-5



RECEIVED
98 JUN -1 AM 11:12
STATE ENGINEER'S OFFICE