

NW NW 2 6

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 73426
Permit No. 87
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38694
10998-A (Temp)

1. OWNER WASHOE COUNTY WATER RESOURCES ADDRESS AT WELL LOCATION 10998-A (Temp)
MAILING ADDRESS P.O. Box 11130 Coppercloud Street
Reno, NV 89520-0027

2. LOCATION SW NW 1/4 SW NW 1/4 Sec. 23 T 18 R 19 E Washoe County
PERMIT NO. 57161 CU293 CU292T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Loam		0	2	2
Gravel consisting of silt, sand, cobbles and boulders		2	180	178
Gravel consisting of silt, sand and cobbles with minor clay lenses		180	725	545

8. WELL CONSTRUCTION
Depth Drilled 725 Feet Depth Cased 705 Feet
HOLE DIAMETER (BIT SIZE)
From To
28" Inches 0 Feet 100 Feet
20" Inches 100 Feet 725 Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>22</u>		<u>.375</u>	<u>0</u>	<u>100</u>
<u>14</u>		<u>.250</u>	<u>0</u>	<u>705</u>

Perforations:
Type perforation Wire wrap screen
Size perforation .080 slot
From 440 feet to 560 feet
From 580 feet to 700 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type:
Depth of Seal 100 feet Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 0 feet to 725 feet

9. WATER LEVEL
Static water level 331.46 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality Good

Date started April 25, 1998
Date completed June 30, 1998

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>400</u>		<u>1.66 Hrs.</u>
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>500</u>		<u>1.66 Hrs.</u>
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>600</u>		<u>1.66 Hrs.</u>
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>800</u>	<u>142.46'</u>	<u>1.66 Hrs.</u>
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>550</u>	<u>126.94'</u>	<u>72 Hrs.</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen Company Contractor
Address P.O. Box 606 Contractor
Carson City, NV 89702
Nevada contractor's license number issued by the State Contractor's Board 17823
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1564
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8-5-98