

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Permit No. 73440
 Basin 88
 NOTICE OF INTENT NO. 39084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Reed Simmons
 MAILING ADDRESS 121 Andrews Lane
Reno, NV 89511
 ADDRESS AT WELL LOCATION 121 Andrews Lane

2. LOCATION NE 1/4 SW 1/4 Sec. 4 T 17N
 PERMIT NO. WaCo#6154 017-330-24
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
See next line		0	12	12
Multi colored sands & gravels				
Brown clay		12	22	10
Mult colored volcanics		22	40	18
Gravels w/brown clay		40	45	5
Multi colored gravels		45	50	5
See next line		50	60	10
Multi colored coarse sands & grvls				
See next line		60	75	15
Mult colored fine & coarse sand				
See next line		75	100	25
Brown clay w/multi colored grvls				
See next line	x	100	160	60
Multi colored volcanic rock/fractured				

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3"
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
 Contractor
 Address 1600 Mt. Rose Hwy
 Contractor

RENO, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 8-12-98

Date started 8/4/98
 Date completed 8/6/98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>30</u>	<u>120</u>	<u>24</u>