WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73445
Permit No.
Basin 107

NOTICE OF INTENT NO. 39347

1. OWNER ELLIS & DIANE FARIAS
MAILING ADDRESS P.O. BOX 27
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION
2783 HWY 208 - WELLINGTON HILLS, WELLINGTON NEVADA

2. LOCATION SW 1/4 SE 1/4 Sec. 2 T 10 N/S R 23 E LYON County

PERMIT NO. ____ Issued by Water Resources | 10-631-11 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY W/COBLES		0	65	65
FRACTURED ROCK		65	115	50
CLAY W/SM.GRAVEL LAYERS		115	205	90
GRAVEL		205	245	40

Date started 10/1/98, 19__
Date completed 10/7/98, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		3.5 hr.

8. WELL CONSTRUCTION

Depth Drilled 245 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	80	Feet
10-5/8	Inches	80	Feet	245	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		3/16	+1	225

Perforations:
Type perforation MILL SLOT
Size perforation 1/8 X 3
From 185 feet to 225 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 105 feet to 225 feet

9. WATER LEVEL

Static water level 196 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature COOL °F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-12-98