WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73452
Permit No.
Basin 107

NOTICE OF INTENT NO. 39346

1. OWNER RICHARD FULSTONE
MAILING ADDRESS P.O. BOX 34
SMITH VALLEY, NV 89430

ADDRESS AT WELL LOCATION
SOUTH HWY 208 SMITH VALLEY, NEVADA 89430

2. LOCATION NW 1/4 NE 1/4 Sec. 31 T 11 N/S R 24 E LYON County
PERMIT NO. 63716 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [X] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	5
SAND & GRAVEL		5	96	91
CLAY		96	121	25
LARGE SAND & GRAVEL		121	233	112
CLAY		233	248	15
See next line		248	306	58
SAND & GRAVEL W/S CLAY STRINGERS				

Date started 9/29/98, 19__
Date completed 9/30/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		3 HRS

8. WELL CONSTRUCTION
Depth Drilled 306 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-7/8	Inches	0	Feet	306	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.250	+1	300

Perforations:
Type perforation SINGLE ROW MILL SLOT
Size perforation 1/8 X 3
From 180 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 306 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources the on-site driller 2019

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-17-98