WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73457
Permit No.
Basin 105

NOTICE OF INTENT NO. 38841

1. OWNER Jack White
MAILING ADDRESS Gardnerville NV.
ADDRESS AT WELL LOCATION 423 Claire Ct.
Minden NV 89423

2. LOCATION NW ¼ SE ¼ Sec. 22 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-280-41 (Parcel No.) Foothills Area (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Course Cobbles and DG Sands		3	58	55
Very Hard Granite Boulder		58	63	5
Course DG Sand and Cobbles		63	94	31
Quartz and Rusty Granite with small DG Sands		94	115	21
Hard Granite		115	150	35
Fractured Granite Boulders Soft DG Sands	xx	150	185	35

Date started 10-13- 1998
Date completed 10-15 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	185 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	185

Perforations:
Type perforation Mill Slot
Size perforation 3X 5/32
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 65 feet to 185 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address PO Kit Kat DR. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 10-15-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627