WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 73458
Permit No.
Basin 105

NOTICE OF INTENT NO. 38862

1. OWNER Gregg & Becky Tookinson
MAILING ADDRESS P.O. Box 2552 Minden NV.
ADDRESS AT WELL LOCATION Not Given Yet MPNH 19-420-01

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 12 ☒ S R. 19 E. Douglas County
PERMIT NO. (Issued by Water Resources) 19-420-01 (Parcel No.) Foothills (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands and Cobbles and Large Boulders		0	18	18
Coarse DG SANDS		18	73	55
HARD Black & White Granite		73	110	37
Pink & White Granite Quartz		110	135	25
Fractured Granite	X	135	140	5
Rusty DG Sands and Gravels		140	147	7
Fractured Granite small SANDS and Rusty & Green Gravels Solid and HARD	XXX	147	185	38

Date started 10-6, 1998
Date completed 10-10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30-32	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 3/4	0	185

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	185

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 145 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 185' feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. 30-32 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 10-11-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627