

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38835

1. OWNER Mark Evans SECTION 35 CCD ADDRESS AT WELL LOCATION 1426 Willow Creek
 MAILING ADDRESS Gardnerville W. 89410
 2. LOCATION SE 1/4 SE 1/4 Sec. 35 T. 13 S. R. 20 E. Douglas County
 PERMIT NO. SW SW 23-442-05 Parcel No. 1420-35-002-004 Division Name Willow Creek

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>6</u>	<u>3</u>	<u>3</u>
<u>Hard Pan Clay</u>		<u>3</u>	<u>15</u>	<u>12</u>
<u>Coarse Sands and Gravels</u>		<u>15</u>	<u>63</u>	<u>48</u>
<u>Seams of Clay and SANDS</u>		<u>63</u>	<u>87</u>	
<u>Brown Solid Clay</u>		<u>87</u>	<u>130</u>	<u>43</u>
<u>Coarse DR SANDS</u>	<u>XX</u>	<u>130</u>	<u>165</u>	<u>35</u>

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>165</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 145 feet to 165 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 165 feet

9. WATER LEVEL
 Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. 25-30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling Contractor
 Address 20 Kit Kat DR. Carson City W. 89706 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Mark Evans
 By driller performing actual drilling on site or contractor
 Date 8-24-98

Date started 8-21 1998
 Date completed 8-23 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25-30</u>	<u>65</u>	<u>3 HRS</u>

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38835

1. OWNER Marv Evans SECTION 35 (C.D.) ADDRESS AT WELL LOCATION 1426 Willow Creek
 MAILING ADDRESS Gardnerville, NV. 35 Gardnerville, NV. 89410
 2. LOCATION SE 1/4 SE 1/4 Sec 39 T 13 N R 20 E Douglas County
 PERMIT NO. SW SW 23-442-05 Parcel No. 14-20-35-002-000 Subdivision Name Willow Creek

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		6	3	3
Hard Pan Clay		3	15	12
Coarse Sands and Gravels		15	63	48
Seams of Clay and SANDS		63	87	
Brown Solid Clay		87	130	43
Coarse DR SANDS.	XX	130	165	35

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>165</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x3/32
 From 145 feet to 165 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 165 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. 25-30 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well Drilling
 Address 20 Keith Hill Dr. Carson City NV. 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-24-98

Date started 8-21, 1998
 Date completed 8-23, 1998

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25-30</u>	<u>65</u>	<u>3 HRS</u>

RECEIVED
 98 AUG 31 PM 12:30
 STATE ENGINEERS OFFICE

[Handwritten signature and notes]