

OFFICE USE ONLY  
 Log No. 73466  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38858

1. OWNER Dwight Borges ADDRESS AT WELL LOCATION 445 Hansen Ln. Gardnerville NV 89410  
 MAILING ADDRESS PO Box 5905 Stateline NV 89449  
 2. LOCATION SW 1/4 NE 1/4 Sec. 34 T. 13 S R. 19 E County \_\_\_\_\_  
 PERMIT NO. 19-070-23 Parcel No. \_\_\_\_\_ Subdivision Name Feet hills  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Hard Pack Clay</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Brown Sands</u> <u>Surface Water</u>		<u>4</u>	<u>17</u>	<u>13</u>
<u>Course Sand and</u> <u>Pea Gravels</u>		<u>17</u>	<u>38</u>	<u>21</u>
<u>Clay</u>		<u>38</u>	<u>86</u>	<u>48</u>
<u>Gray Sandy Clay</u> <u>and Small DG</u>		<u>86</u>	<u>110</u>	<u>24</u>
<u>Course DG Sands</u>	<u>XXX</u>	<u>110</u>	<u>147</u>	<u>37</u>

8. WELL CONSTRUCTION  
 Depth Drilled 147 Feet Depth Cased 147 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 147 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>147</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3 x 3/32  
 From 127 feet to 147 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 105  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 105 feet to 147 feet

RECEIVED  
 03 SEP 11 AM 10:57  
 STATE ENGINEERING OFFICE

Date started 9-10, 1998  
 Date completed 9-11, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35+</u>	<u>45</u>	<u>3 HRS</u>

9. WATER LEVEL  
 Static water level 4' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 35+ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Capital City Well Drilling Contractor  
 Address 80 Kit Kat Dr. Carson City NV 89206 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael L Hoek  
 By driller performing actual drilling on site or contractor  
 Date 9-11-98